

ACTIVITY HAZARDS ANALYSIS

Date Prepared: February 16, 2010

Project: EC-HMQ

Job: Elictrical Equipment

Prepared By: Karen M. González

Reviewed By: Michael Henry

Risk Assessment Code(RAC):

H

E = Extremely High Risk
 H = High Risk
 M = Moderate Risk
 L = Low Risk

		P r o b a b i l i t y				
		Frequent	Likely	Occasional	Seldom	Unlikely
S e v e r i t y	Catastrophic	E	E	H	H	M
	Critical	E	H	H	M	L
	Marginal	H	M	M	L	L
	Negligible	M	L	L	L	L

Recommended Protective Clothing & Equipment:

Isolating gloves
Likely, Critical

JOB STEPS	HAZARDS	ACTIONS TO ELEMIMATE OR MINIMIZE HAZARDS	EM 385-1-1 (PARA REF)
Electrical Equipment	Physical injury to employee on the job.	<ol style="list-style-type: none"> 1. Use properly and maintain equipment 2. Repair or replace frayed electrical cords, loose or broken wires, broken outlet covers, and receptacles and worn or broken electrical plugs. 3. Keep all liquids away from electrical equipment. <p>Remove or tape down cords. Remove or mark hazards for better visibility.</p>	Section 11